



# Texas Commission on Environmental Quality

*Protecting Texas by Reducing and Preventing Pollution*

## CERTIFICATE OF DELIVERY OF PUBLIC NOTICE TO CUSTOMERS

Public Water System (PWS) name: CITY OF CHILLICOTHE  
PWS ID (7-digit number required): TX0990001  
Type violation: TTHM MCL, LRAA  
Time Period of violation: fourth quarter of 2023

The PWS named above has distributed the Public Notice (PN) for the type of violation and time period listed above by:

**Mail or direct delivery, to bill-paying customers as required by 30 TAC §290.122(b)(2)(A) for community water systems; and**

The information contained in this public notification is correct and complies with required public notification content in accordance with 30 TAC §290.122 and;

Made an adequate good-faith effort to reach non-bill-paying consumers by appropriate methods (check all below that apply):

- Posting the PN on the internet at www.chillicothetx.com
- Mailing the PN to postal patrons within the service area that do not receive a bill
- Advertising the PN in news media
- Publication of PN in local newspaper
- Posting the PN in public places
- Delivery of multiple copies to single bill addresses serving several persons
- Delivery to community organizations
- Email notification

Date of Delivery to Customers 1-17-24

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations."

Certified by: Name (print): Michelle Stovall Title: City Secretary  
Phone: 940 852 5211  
Signature: Michelle Stovall Date Signed: 1-17-24

Mail a copy of this completed form and a copy of the Public Notice that was delivered to your customers to:

**TCEQ - Drinking Water Inventory & Protection Team**  
**Attn: Public Notice (MC-155)**  
**P. O. Box 13087**  
**Austin, TX 78711-3087**

# *City of Chillicothe*

P.O. Box 546

Chillicothe, Texas 79225

940-852-5211

Fax: 940-852-5797

The Texas Commission on Environmental Quality (TCEQ) has notified the **CITY OF CHILLICOTHE TX099001** water system that the drinking water being supplied to customers has exceeded the Maximum Contaminant Level (MCL) for total trihalomethanes. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for total trihalomethanes at 0.080 milligrams per liter (mg/L) based on a locational running annual average (LRAA), and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for total trihalomethanes indicates a compliance value in quarter four 2023 of 0.088 mg/L for DBP2-01.

Trihalomethanes are a group of volatile organic compounds that are formed when chlorine, added to the water during the treatment process for disinfection, reacts with naturally-occurring organic matter in the water.

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidney, or central nervous systems, and may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue:

We are in the process of repairing our tank. We have finally received the mixer and it has been repaired but we are still waiting on the vent to be delivered.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have any questions regarding this matter, you may contact Nicky Richter, Public Water Official at (940) 852-5211.

Posted/Deliveredon: 01/17/2024

**Violation Sample Results Report:  
CITY OF CHILLICOTHE PWS ID: TX0990001**

DBP2-01

Violation ID Number	Monitoring Period	Violation Description	Analyte Description	Calculated Compliance Value
90059770	4Q2023	MCL, LRAA	TTHM	0.088 mg/L

**Results for Quarter 4 of 2023: TTHM**

Sample ID:Q2352346003 12/07/2023 DBP2-01 507 AVENUE S SOUTH, CHILLICO 88.2 µg/L

**Results for Quarter 3 of 2023: TTHM**

Sample ID:Q2340361003 09/19/2023 DBP2-01 507 AVENUE S SOUTH, CHILLICO 75.6 µg/L

**Results for Quarter 2 of 2023: TTHM**

Sample ID:Q2320361003 05/31/2023 DBP2-01 507 AVENUE S SOUTH, CHILLICO 75.6 µg/L

**Results for Quarter 1 of 2023: TTHM**

Sample ID:Q2307780007 02/27/2023 DBP2-01 507 AVENUE S SOUTH, CHILLICO 113.0 µg/L